

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
0	<b>1001.1 Scoping.</b> Dwelling units and sleeping units required to be Accessible units, Type A units, Type B units, Type C (Visitable) units or units with accessible communication features by the scoping provisions adopted by the administrative authority shall comply with the applicable provisions of Chapter 10.		
1	<b>1002.1 General.</b> Accessible units shall comply with Section 1002.	<b>1003.1 General.</b> Type A units shall comply with Section 1003.	<b>1004.1 General.</b> Type B units shall comply with Section 1004.
2	<b>1002.2 Primary Entrance.</b> The accessible primary entrance shall be on an accessible route from public and common areas. The primary entrance shall not be to a bedroom unless it is the only entrance.	<b>1003.2 Primary Entrance.</b> The accessible primary entrance shall be on an accessible route from public and common areas. The primary entrance shall not be to a bedroom unless it is the only entrance.	<b>1004.2 Primary Entrance.</b> The accessible primary entrance shall be on an accessible route from public and common areas. The primary entrance shall not be to a bedroom unless it is the only entrance.
3	<b>1002.3 Accessible Route.</b> Accessible routes within Accessible units shall comply with Section 1002.3.	<b>1003.3 Accessible Route.</b> Accessible routes within Type A units shall comply with Section 1003.3.	<b>1004.3 Accessible Route.</b> Accessible routes within Type B units shall comply with Section 1004.3.
	<b>1002.3.1 Location.</b> At least one accessible route shall connect all spaces and elements that are a part of the unit. Accessible routes shall coincide with or be located in the same area as a general circulation path.  <b>EXCEPTION:</b> An accessible route is not required to unfinished attics and unfinished basements that are part of the unit.	<b>1003.3.1 Location.</b> At least one accessible route shall connect all spaces and elements that are a part of the unit. Accessible routes shall coincide with or be located in the same area as a general circulation path.  <b>EXCEPTION:</b> An accessible route is not required to unfinished attics and unfinished basements that are part of the unit.	<b>1004.3.1 Location.</b> At least one accessible route shall connect all spaces and elements that are a part of the unit. Accessible routes shall coincide with or be located in the same area as a general circulation path.  <b>EXCEPTIONS:</b> <ol style="list-style-type: none"> <li>1. An accessible route is not required to unfinished attics and unfinished basements that are part of the unit.</li> <li>2. One of the following is not required to be on an accessible route:               <ol style="list-style-type: none"> <li>2.1 A raised floor area in a portion of a living, dining, or sleeping room; or</li> <li>2.2 A sunken floor area in a portion of a living, dining, or sleeping room; or</li> <li>2.3 A mezzanine that does not have plumbing fixtures or an enclosed habitable space.</li> </ol> </li> </ol>




Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
	<p><b>1002.3.2 Turning Space.</b> All rooms served by an accessible route shall provide a turning space complying with Section 304.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>1. A turning space shall not be required in toilet rooms and bathrooms that are not required to comply with Section 1002.11.2.</li> <li>2. A turning space is not required within closets or pantries that are 48 inches (1220 mm) maximum in depth.</li> </ol>	<p><b>1003.3.2 Turning Space.</b> All rooms served by an accessible route shall provide a turning space complying with Section 304.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>1. A turning space shall not be required in toilet rooms and bathrooms that are not required to comply with Section 1003.11.2.</li> <li>2. A turning space is not required within closets or pantries that are 48 inches (1220 mm) maximum in depth.</li> </ol>	
	<p><b>1002.3.3 Components.</b> Accessible routes shall consist of one or more of the following elements: walking surfaces with a slope not steeper than 1:20, doors and doorways, ramps, elevators, and platform lifts.</p>	<p><b>1003.3.3 Components.</b> Accessible routes shall consist of one or more of the following elements: walking surfaces with a slope not steeper than 1:20, doors and doorways, ramps, elevators, and platform lifts.</p>	<p><b>1004.3.2 Components.</b> Accessible routes shall consist of one or more of the following elements: walking surfaces with a slope not steeper than 1:20, doors and doorways, ramps, elevators, and platform lifts.</p>
4	<p><b>1002.4 Walking Surfaces.</b> Walking surfaces that are part of an accessible route shall comply with Section 403.</p>	<p><b>1003.4 Walking Surfaces.</b> Walking surfaces that are part of an accessible route shall comply with Section 403.</p>	<p><b>1004.4 Walking Surfaces.</b> Walking surfaces that are part of an accessible route shall comply with Section 1004.4.</p> <p><b>1004.4.1 Clear Width.</b> Clear width of an accessible route shall comply with Section 403.5.</p> <p><b>1004.4.2 Changes in Level.</b> Changes in level shall comply with Section 303.</p> <p><b>EXCEPTION:</b> Where exterior deck, patio or balcony surface materials are impervious, the finished exterior impervious surface shall be 4 inches (100 mm) maximum below the floor level of the adjacent interior spaces of the unit.</p>

 Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
5	<p><b>1002.5 Doors and Doorways.</b> The primary entrance door to the unit, and all other doorways intended for user passage, shall comply with Section 404.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>Existing doors to hospital patient sleeping rooms shall be exempt from the requirement for space at the latch side provided the door is 44 inches (1120 mm) minimum in width.</li> <li>In toilet rooms and bathrooms not required to comply with Section 1002.11.2, maneuvering clearances required by Section 404.2.3 are not required on the toilet room or bathroom side of the door.</li> <li>A turning space between doors in a series as required by Section 404.2.5 is not required.</li> <li>Storm and screen doors are not required to comply with Section 404.2.5.</li> <li>Communicating doors between individual sleeping units are not required to comply with Section 404.2.5.</li> </ol>	<p><b>1003.5 Doors and Doorways.</b> The primary entrance door to the unit, and all other doorways intended for user passage, shall comply with Section 404.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>Thresholds at exterior sliding doors shall be permitted to be 3/4 inch (19 mm) maximum in height, provided they are beveled with a slope not greater than 1:2.</li> <li>In toilet rooms and bathrooms not required to comply with Section 1003.11.2, maneuvering clearances required by Section 404.2.3 are not required on the toilet room or bathroom side of the door.</li> <li>A turning space between doors in a series as required by Section 404.2.5 is not required.</li> <li>Storm and screen doors are not required to comply with Section 404.2.5.</li> <li>Communicating doors between individual sleeping units are not required to comply with Section 404.2.5.</li> </ol>	<p><b>1004.5 Doors and Doorways.</b> Doors and doorways shall comply with Section 1004.5.</p> <p><b>1004.5.1 Primary Entrance Door.</b> The primary entrance door to the unit shall comply with Section 404.</p> <p><b>EXCEPTION:</b> (see below)</p> <p>Storm and screen doors serving individual dwelling or sleeping units are not required to comply with Section 404.2.5.</p>



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
	6. At other than the primary entrance door, where exterior space dimensions of balconies are less than the required maneuvering clearance, door maneuvering clearance is not required on the exterior side of the door.	6. At other than the primary entrance door, where exterior space dimensions of balconies are less than the required maneuvering clearance, door maneuvering clearance is not required on the exterior side of the door.	
			<b>1004.5.2 User Passage Doorways.</b> Doorways intended for user passage shall comply with Section 1004.5.2.
			<b>1004.5.2.1 Clear Width.</b> Doorways shall have a clear opening of 31 <sup>3</sup> / <sub>4</sub> inches (810 mm) minimum. Clear opening of swinging doors shall be measured between the face of the door and stop, with the door open 90 degrees.
			<b>1004.5.2.1.1 Double Leaf Doorways.</b> Where the operable parts on an inactive leaf of a double leaf doorway are located more than 48 inches (1220 mm) or less than 15 inches (380 mm) above the floor, the active leaf shall provide the clearance required by Section 1004.5.2.1.
			<b>1004.5.2.2 Thresholds.</b> Thresholds shall comply with Section 303. <b>EXCEPTION:</b> Thresholds at exterior sliding doors shall be permitted to be <sup>3</sup> / <sub>4</sub> inch (19 mm) maximum in height, provided they are beveled with a slope not steeper than 1:2.
			<b>1004.5.2.3 Automatic Doors.</b> Automatic doors shall comply with Section 404.3.
6	<b>1002.6 Ramps.</b> Ramps shall comply with Section 405.	<b>1003.6 Ramps.</b> Ramps shall comply with Section 405.	<b>1004.6 Ramps.</b> Ramps shall comply with Section 405.
7	<b>1002.7 Elevators.</b> Elevators within the unit shall comply with Section 407, 408, or 409.	<b>1003.7 Elevators.</b> Elevators within the unit shall comply with Section 407, 408, or 409.	<b>1004.7 Elevators.</b> Elevators within the unit shall comply with Section 407, 408, or 409.
8	<b>1002.8 Platform Lifts.</b> Platform lifts within the unit shall comply with Section 410.	<b>1003.8 Platform Lifts.</b> Platform lifts within the unit shall comply with Section 410.	<b>1004.8 Platform Lifts.</b> Platform lifts within the unit shall comply with Section 410.



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
9	<p><b>1002.9 Operable Parts.</b> Lighting controls, electrical panelboards, electrical switches and receptacle outlets, environmental controls, appliance controls, operating hardware for operable windows, plumbing fixture controls, and user controls for security or intercom systems shall comply with Section 309.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>1. Receptacle outlets serving a dedicated use.</li> <li>2. Where two or more receptacle outlets are provided in a kitchen above a length of counter top that is uninterrupted by a sink or appliance, one receptacle outlet shall not be required to comply with Section 309.</li> <li>3. Floor receptacle outlets.</li> <li>4. HVAC diffusers.</li> <li>5. Controls mounted on ceiling fans.</li> </ol>	<p><b>1003.9 Operable Parts.</b> Lighting controls, electrical panel boards, electrical switches and receptacle outlets, environmental controls, appliance controls, operating hardware for operable windows, plumbing fixture controls, and user controls for security or intercom systems shall comply with Section 309.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>1. Receptacle outlets serving a dedicated use.</li> <li>2. Where two or more receptacle outlets are provided in a kitchen above a length of counter top that is uninterrupted by a sink or appliance, one receptacle outlet shall not be required to comply with Section 309.</li> <li>3. Floor receptacle outlets.</li> <li>4. HVAC diffusers.</li> <li>5. Controls mounted on ceiling fans.</li> </ol>	<p><b>1004.9 Operable Parts.</b> Lighting controls, electrical switches and receptacle outlets, environmental controls, electrical panelboards, and user controls for security or intercom systems shall comply with Sections 309.2 and 309.3.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>1. Receptacle outlets serving a dedicated use.</li> <li>2. Where two or more receptacle outlets are provided in a kitchen above a length of counter top that is uninterrupted by a sink or appliance, one receptacle outlet shall not be required to comply with Section 309.</li> <li>3. Floor receptacle outlets.</li> <li>4. HVAC diffusers.</li> <li>5. Controls mounted on ceiling fans.</li> <li>6. Controls or switches mounted on appliances.</li> <li>7. Plumbing fixture controls.</li> <li>9. Where redundant controls other than light switches are provided for a single element, one control in each space shall not be required to be accessible.</li> </ol>




Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
	<p>7. Reset buttons and shut-offs serving appliances, piping and plumbing fixtures.</p> <p>8. Electrical panelboards shall not be required to comply with Section 309.4.</p>	<p>7. Reset buttons and shut-offs serving appliances, piping and plumbing fixtures.</p> <p>8. Electrical panelboards shall not be required to comply with Section 309.4.</p>	<p>8. Reset buttons and shut-offs serving appliances, piping and plumbing fixtures.</p> <p>10. Within kitchens and bathrooms, lighting controls, electrical switches and receptacle outlets are permitted to be located over cabinets with counter tops 36 inches (915 mm) maximum in height and 25-1/2 inches (650 mm) maximum in depth.</p> <p><i>(note numbers are reordered to show similarities and improve readability)</i></p>
10	<p><b>1002.10 Laundry Equipment.</b> Washing machines and clothes dryers shall comply with Section 611.</p>	<p><b>1003.10 Laundry Equipment.</b> Washing machines and clothes dryers shall comply with Section 611.</p>	<p><b>1004.10 Laundry Equipment.</b> Washing machines and clothes dryers shall comply with Section 1004.10.</p> <p><b>1004.10.1 Clear Floor Space.</b> A clear floor space complying with Section 305.3, shall be provided. A parallel approach shall be provided for a top loading machine. A forward or parallel approach shall be provided for a front loading machine.</p>
11	<p><b>1002.11 Toilet and Bathing Facilities.</b> At least one toilet and bathing facility shall comply with Section 1002.11.2. All other toilet and bathing facilities shall comply with Section 1002.11.1</p>	<p><b>SEE DETAILED COMPARISON AT END OF DOCUMENT</b></p>	
		<p><b>1003.11 Toilet and Bathing Facilities.</b> At least one toilet and bathing facility shall comply with Section 1003.11.2. All toilet and bathing facilities shall comply with Section 1003.11.1.</p>	<p><b>1004.11 Toilet and Bathing Facilities.</b> Toilet and bathing fixtures shall comply with Section 1004.11.</p> <p><b>EXCEPTION:</b> Fixtures on levels not required to be accessible.</p>

 Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
	<p><b>1002.11.1 Grab Bars and Shower Seat Reinforcement.</b> At fixtures in toilet and bathing facilities not required to comply with Section 1002.11.2, reinforcement in accordance with Section 1004.11.1 shall be provided.</p> <p><b>EXCEPTION:</b> Reinforcement is not required where Type B units are not provided in the structure.</p>	<p><b>1003.11.1 Grab Bar and Shower Seat Reinforcement.</b> Reinforcement shall be provided for the future installation of grab bars complying with Section 604.5 at water closets; grab bars complying with Section 607.4 at bathtubs; and for grab bars and shower seats complying with Sections 608.3, 608.2.1.3, 608.2.2.3 and 608.2.3.2 at shower compartments.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>At fixtures not required to comply with Section 1003.11.2, reinforcement in accordance with Section 1004.11.1 shall be permitted.</li> <li>Reinforcement is not required in a room containing only a lavatory and a water closet, provided the room does not contain the only lavatory or water closet on the accessible level of the dwelling unit.</li> <li>Reinforcement for the water closet side wall vertical grab bar component required by Section 604.5 is not required.</li> </ol>	<p><b>1004.11.1 Grab Bar and Shower Seat Reinforcement.</b> Reinforcement shall be provided for the future installation of grab bars and shower seats at water closets, bathtubs, and shower compartments. Where walls are located to permit the installation of grab bars and seats complying with Section 604.5 at water closets; grab bars complying with Section 607.4 at bathtubs; and for grab bars and shower seats complying with Sections, 608.3, 608.2.1.3, 608.2.2.3 and 608.2.3.2 at shower compartments; reinforcement shall be provided for the future installation of grab bars and seats complying with those requirements.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>In a room containing only a lavatory and a water closet, reinforcement is not required provided the room does not contain the only lavatory or water closet on the accessible level of the unit.</li> <li>At water closets reinforcement for the side wall vertical grab bar component required by Section 604.5 is not required.</li> <li>At water closets where wall space will not permit a grab bar complying with Section 604.5.2, reinforcement for a rear wall grab bar 24 inches (610 mm) minimum in length centered on the water closet shall be provided.</li> </ol>



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
		<p>4. Where the lavatory overlaps the water closet clearance in accordance with the exception to Section 1003.11.2.4.4 reinforcement at the water closet rear wall for a 24-inch (610 mm) minimum length grab bar, centered on the water closet, shall be provided.</p>	<p>4. At water closets where a side wall is not available for a 42-inch (1065 mm) grab bar complying with 604.5.1, reinforcement for a sidewall grab bar, 24 inches (610 mm) minimum in length, located 12 inches (305 mm) maximum from the rear wall, shall be provided.</p> <p>5. At water closets where a side wall is not available for a 42-inch (1065 mm) grab bar complying with Section 604.5.1 reinforcement for a swing-up grab bar complying with Section 1004.11.1.1 shall be permitted.</p> <p>6. At water closets where a side wall is not available for a 42-inch (1065 mm) grab bar complying with 604.5.1 reinforcement for two swing-up grab bars complying with Section 1004.11.1.1 shall be permitted to be installed in lieu of reinforcement for rear wall and side wall grab bars.</p> <p>7. In shower compartments larger than 36 inches (915 mm) in width and 36 inches (915 mm) in depth reinforcement for a shower seat is not required.</p>
			<p><b>1004.11.1.1 Swing-up Grab Bars.</b> A clearance of 18 inches (455 mm) minimum from the centerline of the water closet to any side wall or obstruction shall be provided where reinforcement for swing-up grab bars is provided. When the approach to the water closet is from the side, the 18 inches (455 mm) minimum shall be on the side opposite the direction of approach. Reinforcement shall accommodate a swing-up grab bar centered 15-3/4 inches (400 mm) from the centerline of</p>



Indicates same language



# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
			<p>the water closet and 28 inches (710 mm) minimum in length, measured from the wall to the end of the horizontal portion of the grab bar. Reinforcement shall accommodate a swing-up grab bar with a height in the down position of 33 inches (840 mm) minimum and 36 inches (915 mm) maximum. Reinforcement shall be adequate to resist forces in accordance with Section 609.8.</p> <p><b>EXCEPTION:</b> Where a water closet is positioned with a wall to the rear and to one side, the centerline of the water closet shall be 16 inches (405 mm) minimum and 18 inches (455 mm) maximum from the sidewall.</p>
	<p><b>1002.11.2 Accessible Toilet and Bathing Facility.</b> At least one toilet and bathing facility shall comply with Section 603. At least one lavatory, one water closet and either a bathtub or shower within the unit shall comply with Sections 604 through 610. The accessible toilet and bathing fixtures shall be in a single toilet/bathing area, such that travel between fixtures does not require travel through other parts of the unit.</p>		
		<p><b>1003.11.2 General.</b> At least one toilet and bathing facility shall comply with Section 1003.11.2. At least one lavatory, one water closet and either a bathtub or shower within the unit shall comply with Section 1003.11.2. The accessible toilet and bathing fixtures shall be in a single toilet/bathing area, such that travel between fixtures does not require travel through other parts of the unit.</p>	
			<p><b>1004.11.2 Clear Floor Space.</b> Clear floor spaces required by Section 1004.11.3.1 (Option A) or 1004.11.3.2 (Option B) shall comply with Sections 1004.11.2 and 305.3.</p>



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
		<p><b>1003.11.2.1 Doors.</b> Doors shall not swing into the clear floor space or clearance for any fixture.</p> <p><b>EXCEPTION:</b> Where a clear floor space complying with Section 305.3 is provided within the room beyond the arc of the door swing.</p>	<p><b>1004.11.2.1 Doors.</b> Doors shall not swing into the clear floor space or clearance for any fixture.</p> <p><b>EXCEPTION:</b> Where a clear floor space complying with Section 305.3, excluding knee and toe clearances under elements, is provided within the room beyond the arc of the door swing.</p>
	<p><b>1002.11.2.1 Vanity Counter Top Space.</b> If vanity counter top space is provided in dwelling or sleeping units not required to be Accessible units within the same facility, equivalent vanity counter top space, in terms of size and proximity to the lavatory, shall also be provided in Accessible units.</p>		
		<p><b>1003.11.2.2 Lavatory.</b> Lavatories shall comply with Section 606.</p> <p><b>EXCEPTION:</b> Cabinetry shall be permitted under the lavatory, provided the following criteria are met:</p> <ul style="list-style-type: none"> <li>(a) The cabinetry can be removed without removal or replacement of the lavatory;</li> <li>(b) The floor finish extends under the cabinetry; and</li> <li>(c) The walls behind and surrounding the cabinetry are finished.</li> </ul>	
			<p><b>1004.11.2.2 Knee and Toe Clearance.</b> Clear floor space at fixtures shall be permitted to include knee and toe clearances complying with Section 306.</p>
	<p><b>1002.11.2.2 Mirrors.</b> Mirrors above accessible lavatories shall have the bottom edge of the reflecting surface 40 inches (1015 mm) maximum above the floor.</p>	<p><b>1003.11.2.3 Mirrors.</b> Mirrors above accessible lavatories shall have the bottom edge of the reflecting surface 40 inches (1015 mm) maximum above the floor.</p>	



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
		<p><b>1003.11.2.4 Water Closet.</b> Water closets shall comply with Section 1003.11.2.4.</p>	
		<p><b>1003.11.2.4.1 Location.</b> The water closet shall be positioned with a wall to the rear and to one side. The centerline of the water closet shall be 16 inches (405 mm) minimum and 18 inches (455 mm) maximum from the sidewall.</p>	
		<p><b>1003.11.2.4.2 Clearance Width.</b> A clearance around the water closet shall be 60 inches (1525 mm) minimum in width, measured perpendicular from the side wall.</p>	
		<p><b>1003.11.2.4.3 Clearance Depth.</b> Clearance around the water closet shall be 56 inches (1420 mm) minimum in depth, measured perpendicular from the rear wall.</p>	
		<p><b>1003.11.2.4.4 Clearance Overlap.</b> The required clearance around the water closet shall be permitted to overlap the water closet, associated grab bars, paper dispensers, coat hooks, shelves, accessible routes, clear floor space required at other fixtures, and the wheelchair turning space. No other fixtures or obstructions shall be located within the required water closet clearance.</p> <p><b>EXCEPTION:</b> A lavatory measuring 24 inches (610 mm) maximum in depth and complying with Section 1003.11.2.2 shall be permitted on the rear wall 18 inches (455 mm) minimum from the centerline of the water closet to the side edge of the lavatory where the clearance at the water closet is 66 inches (1675 mm) minimum measured perpendicular from the rear wall.</p>	



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
		<p><b>1003.11.2.4.5 Height.</b> The top of the water closet seat shall be 15 inches (380 mm) minimum and 19 inches (485 mm) maximum above the floor, measured to the top of the seat.</p>	
		<p><b>1003.11.2.4.6 Flush Controls.</b> Flush controls shall be hand-operated or automatic. Hand operated flush controls shall comply with Section 309. Hand-operated flush controls shall be located on the open side of the water closet.</p>	
		<p><b>1003.11.2.5 Bathing Fixtures.</b> The accessible bathing fixture shall be a bathtub complying with Section 1003.11.2.5.1 or a shower compartment complying with Section 1003.11.2.5.2.</p>	
		<p><b>1003.11.2.5.1 Bathtub.</b> Bathtubs shall comply with Section 607.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>1. The removable in-tub seat required by Section 607.3 is not required.</li> <li>2. Counter tops and cabinetry shall be permitted at one end of the clearance, provided the following criteria are met:               <ol style="list-style-type: none"> <li>(a) The countertop and cabinetry can be removed;</li> <li>(b) The floor finish extends under the countertop and cabinetry; and</li> <li>(c) The walls behind and surrounding the countertop and cabinetry are finished.</li> </ol> </li> </ol>	
		<p><b>1003.11.2.5.2 Shower.</b> Showers shall comply with Section 608.</p> <p><b>EXCEPTION:</b> At standard roll-in shower compartments complying with Section 608.2.2, lavatories, counter tops and</p>	



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
		cabinetry shall be permitted at one end of the clearance, provided the following criteria are met: <ul style="list-style-type: none"> <li>(a) The countertop and cabinetry can be removed;</li> <li>(b) The floor finish extends under the countertop and cabinetry; and</li> <li>(c) The walls behind and surrounding the countertop and cabinetry are finished.</li> </ul>	
			<b>1004.11.3 Toilet and Bathing Areas.</b> Either all toilet and bathing areas provided shall comply with Section 1004.11.3.1 (Option A), or one toilet and bathing area shall comply with Section 1004.11.3.2 (Option B).
			<b>1004.11.3.1 Option A.</b> Each fixture provided shall comply with Section 1004.11.3.1. <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>1. Where multiple lavatories are provided in a single toilet and bathing area such that travel between fixtures does not require travel through other parts of the unit, not more than one lavatory is required to comply with Section 1004.11.3.1.</li> <li>2. A lavatory and a water closet in a room containing only a lavatory and a water closet, provided the room does not contain the only lavatory or water closet on the accessible level of the unit.</li> </ol>
			<b>1004.11.3.2 Option B.</b> One of each type of fixture provided shall comply with Section 1004.11.3.2. The accessible fixtures shall be in a single toilet/bathing area, such that travel between fixtures does not require travel through other parts of the unit.



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
12	<p><b>1002.12 Kitchens and kitchenettes.</b> Kitchens and kitchenettes shall comply with Section 804. At least one work surface, 30 inches (760 mm) minimum in length, shall comply with Section 902.</p> <p><b>EXCEPTION:</b> Spaces that do not provide a cooktop or conventional range shall not be required to provide an accessible work surface.</p>	<p><b>1003.12 Kitchens and kitchenettes.</b> Kitchens and kitchenettes shall comply with Section 1003.12.</p> <p><b>NCBC 1109.4 Kitchens and kitchenettes.</b> <i>Where kitchens and kitchenettes are provided in accessible spaces or rooms, they shall be accessible in accordance with ICC A117.1</i></p> <ol style="list-style-type: none"> <li>1. A minimum 60-inch (1524 mm) clear turning space shall be provided within the kitchen of a Type A unit.</li> <li>2. A maximum 6-inch (150 mm) deep by minimum 9-inch (230 mm) high toe space beneath a cabinet shall be permitted to provide part of the 60-inch (1524 mm) clear floor area on one side only.</li> </ol>	<p><b>1004.12 Kitchens and kitchenettes.</b> Kitchens and kitchenettes shall comply with Section 1004.12.</p>
		<p><b>1003.12.1 Clearance.</b> Clearance complying with Section 1003.12.1 shall be provided.</p>	<p><b>1004.12.1 Clearance.</b> Clearance complying with Section 1004.12.1 shall be provided.</p>
		<p><b>1003.12.1.1 Minimum Clearance.</b> Clearance between all opposing base cabinets, counter tops, appliances, or walls within kitchen work areas shall be 40 inches (1015mm) minimum.</p>	<p><b>1004.12.1.1 Minimum Clearance.</b> Clearance between all opposing base cabinets, counter tops, appliances, or walls within kitchen work areas shall be 40 inches (1015mm) minimum.</p>
		<p><b>1003.12.1.2 U-Shaped Kitchens.</b> In kitchens with counters, appliances, or cabinets on three contiguous sides, clearance between all opposing base cabinets, countertops, appliances, or walls within kitchen work areas shall be 60 inches (1525 mm) minimum.</p>	<p><b>1004.12.1.2 U-Shaped Kitchens.</b> In kitchens with counters, appliances, or cabinets on three contiguous sides, clearance between all opposing base cabinets, countertops, appliances, or walls within kitchen work areas shall be 60 inches (1525 mm) minimum.</p>
		<p><b>1003.12.2 Clear Floor Space.</b> Clear floor spaces required by Sections 1003.12.3 through 1003.12.5 shall comply with Section 305.</p>	<p><b>1004.12.2 Clear Floor Space.</b> Clear floor space at appliances shall comply with Sections 1004.12.2 and 305.3.</p>



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
		<p><b>1003.12.3 Work Surface.</b> At least one section of counter shall provide a work surface 30 inches (760 mm) minimum in length complying with Section 1003.12.3.</p>	
		<p><b>1003.12.3.1 Clear Floor Space.</b> A clear floor space, positioned for a forward approach to the work surface, shall be provided. Knee and toe clearance complying with Section 306 shall be provided. The clear floor space shall be centered on the work surface.</p> <p><b>EXCEPTION:</b> Cabinetry shall be permitted under the work surface, provided the following criteria are met:</p> <ul style="list-style-type: none"> <li>(a) The cabinetry can be removed without removal or replacement of the work surface,</li> <li>(b) The floor finish extends under the cabinetry, and</li> <li>(c) The walls behind and surrounding the cabinetry are finished.</li> </ul>	
		<p><b>1003.12.3.2 Height.</b> The work surface shall be 34 inches (865 mm) maximum above the floor.</p> <p><b>EXCEPTION:</b> A counter that is adjustable to provide a work surface at variable heights 29 inches (735 mm) minimum and 36 inches (915 mm) maximum above the floor, or that can be relocated within that range without cutting the counter or damaging adjacent cabinets, walls, doors, and structural elements, shall be permitted.</p>	
		<p><b>1003.12.3.3 Exposed Surfaces.</b> There shall be no sharp or abrasive surfaces under the exposed portions of work surface counters.</p>	



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
		<p><b>1003.12.4 Sink.</b> The sink shall comply with Section 1003.12.4.</p>	<p><b>1004.12.2.1 Sink.</b> A clear floor space, positioned for a parallel approach to the sink, shall be provided. The clear floor space shall be centered on the sink bowl.</p> <p><b>EXCEPTION:</b> A sink with a forward approach complying with Section 1003.12.4.1.</p>
		<p><b>1003.12.4.1 Clear Floor Space.</b> A clear floor space, positioned for a forward approach to the sink, shall be provided. Knee and toe clearance complying with Section 306 shall be provided.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>1. The requirement for knee and toe clearance shall not apply to more than one bowl of a multi-bowl sink.</li> <li>2. Cabinetry shall be permitted to be added under the sink, provided the following criteria are met:               <ol style="list-style-type: none"> <li>(a) The cabinetry can be removed without removal or replacement of the sink,</li> <li>(b) The floor finish extends under the cabinetry, and</li> <li>(c) The walls behind and surrounding the cabinetry are finished.</li> </ol> </li> </ol>	



Indicates same language



# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
		<p><b>1003.12.4.2 Height.</b> The front of the sink shall be 34 inches (865 mm) maximum above the floor, measured to the higher of the rim or counter surface.</p> <p><b>EXCEPTION:</b> A sink and counter that is adjustable to variable heights 29 inches (735 mm) minimum and 36 inches (915 mm) maximum above the floor, or that can be relocated within that range without cutting the counter or damaging adjacent cabinets, walls, doors and structural elements, provided rough-in plumbing permits connections of supply and drain pipes for sinks mounted at the height of 29 inches (735 mm), shall be permitted.</p>	
		<p><b>1003.12.4.3 Faucets.</b> Faucets shall comply with Section 309.</p>	
		<p><b>1003.12.4.4 Exposed Pipes and Surfaces.</b> Water supply and drain pipes under sinks shall be insulated or otherwise configured to protect against contact. There shall be no sharp or abrasive surfaces under sinks.</p>	
		<p><b>1003.12.5 Appliances.</b> Where provided, kitchen appliances shall comply with Section 1003.12.5.</p>	
		<p><b>1003.12.5.1 Operable Parts.</b> All appliance controls shall comply with Section 1003.9.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>1. Appliance doors and door latching devices shall not be required to comply with Section 309.4.</li> <li>2. Bottom-hinged appliance doors, when in the open position, shall not be required to comply with Section 309.3.</li> </ol>	



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
		<b>1003.12.5.2 Clear Floor Space.</b> A clear floor space, positioned for a parallel or forward approach, shall be provided at each kitchen appliance.	
		<b>1003.12.5.3 Dishwasher.</b> A clear floor space, positioned adjacent to the dishwasher door, shall be provided. The dishwasher door in the open position shall not obstruct the clear floor space for the dishwasher or an adjacent sink.	<b>1004.12.2.2 Dishwasher.</b> A clear floor space, positioned for a parallel or forward approach to the dishwasher, shall be provided. The dishwasher door in the open position shall not obstruct the clear floor space for the dishwasher.
		<b>1003.12.5.4 Cooktop.</b> Cooktops shall comply with Section 1003.12.5.4.	<b>1004.12.2.3 Cooktop.</b> Cooktops shall comply with Section 1004.12.2.3.
		<b>1003.12.5.4.1 Approach.</b> A clear floor space, positioned for a parallel or forward approach to the cooktop, shall be provided.	<b>1004.12.2.3.1 Approach.</b> A clear floor space, positioned for a parallel or forward approach to the cooktop, shall be provided.
		<b>1003.12.5.4.2 Forward approach.</b> Where the clear floor space is positioned for a forward approach, knee and toe clearance complying with Section 306 shall be provided. The underside of the cooktop shall be insulated or otherwise configured to protect from burns, abrasions, or electrical shock.	<b>1004.12.2.3.2 Forward approach.</b> Where the clear floor space is positioned for a forward approach, knee and toe clearance complying with Section 306 shall be provided. The underside of the cooktop shall be insulated or otherwise configured to prevent burns, abrasions, or electrical shock.
		<b>1003.12.5.4.3 Parallel approach.</b> Where the clear floor space is positioned for a parallel approach, the clear floor space shall be centered on the appliance.	<b>1004.12.2.3.3 Parallel approach.</b> Where the clear floor space is positioned for a parallel approach, the clear floor space shall be centered on the appliance.
		<b>1003.12.5.4.4 Controls.</b> The location of controls shall not require reaching across burners.	
		<b>1003.12.5.5 Oven.</b> Ovens shall comply with Section 1003.12.5.5. Ovens shall have controls on front panels, on either side of the door.	<b>1004.12.2.4 Oven.</b> A clear floor space, positioned for a parallel or forward approach adjacent to the oven shall be provided. The oven door in the open position shall not obstruct the clear floor space for the oven.



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
		<b>1003.12.5.5.1 Clear floor space.</b> A clear floor space shall be provided. The oven door in the open position shall not obstruct the clear floor space for the oven.	
		<b>1003.12.5.5.2 Side-Hinged Door Ovens.</b> Side-hinged door ovens shall have a countertop positioned adjacent to the latch side of the oven door.	
		<b>1003.12.5.5.3 Bottom-Hinged Door Ovens.</b> Bottom-hinged door ovens shall have a countertop positioned adjacent to one side of the door.	
		<b>1003.12.5.5.4 Controls.</b> The location of controls shall not require reaching across burners.	
		<b>1003.12.5.6 Refrigerator/Freezer.</b> Combination refrigerators and freezers shall have at least 50 percent of the freezer compartment shelves, including the bottom of the freezer 54 inches (1370 mm) maximum above the floor when the shelves are installed at the maximum heights possible in the compartment. A clear floor space, positioned for a parallel approach to the refrigerator/freezer, shall be provided. The centerline of the clear floor space shall be offset 24 inches (610 mm) maximum from the centerline of the appliance.	<b>1004.12.2.5 Refrigerator/Freezer.</b> A clear floor space, positioned for a parallel approach to the refrigerator/freezer, shall be provided. The centerline of the clear floor space shall be offset 24 inches (610 mm) maximum from the centerline of the appliance.
			<b>1004.12.2.6 Trash Compactor.</b> A clear floor space, positioned for a parallel or forward approach to the trash compactor, shall be provided.
13	<b>1002.13 Windows.</b> Windows shall comply with Section 1002.13.	<b>1003.13 Windows.</b> Windows shall comply with Section 1003.13.	
	<b>1002.13.1 Natural ventilation.</b> Operable windows required to provide natural ventilation shall comply with Sections 309.2 and 309.3.	<b>1003.13.1 Natural ventilation.</b> Operable windows required to provide natural ventilation shall comply with Sections 309.2 and 309.3.	



Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

#	1002 ACCESSIBLE UNITS	1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS
	<b>1002.13.2 Emergency escape.</b> Operable windows required to provide an emergency escape and rescue opening shall comply with Section 309.2.	<b>1003.13.2 Emergency escape.</b> Operable windows required to provide an emergency escape and rescue opening shall comply with Section 309.2.	
14	<b>1002.14 Storage Facilities.</b> Where storage facilities are provided, at least one of each type shall comply with Section 905.  <b>EXCEPTION:</b> Kitchen cabinets shall not be required to comply with Section 1002.14.	<b>1003.14 Storage Facilities.</b> Where storage facilities are provided, at least one of each type shall comply with Section 905.  <b>EXCEPTION:</b> Kitchen cabinets shall not be required to comply with Section 1003.14.	
15	<b>1002.15 Beds.</b> In at least one sleeping area, a minimum of five percent, but not less than one bed shall comply with Section 1002.15.		
	<b>1002.15.1 Clear Floor Space.</b> A clear floor space complying with Section 305 shall be provided on both sides of the bed. The clear floor space shall be positioned for parallel approach to the side of the bed. <b>EXCEPTION:</b> Where a single clear floor space complying with Section 305 positioned for parallel approach is provided between two beds, a clear floor space shall not be required on both sides of the bed.		
	<b>1002.15.2 Bed Frames.</b> At least one bed shall be provided with an open bed frame.		




Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

TOILET AND BATHING FACILITY COMPARISON		
1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS	
	OPTION A	OPTION B
<p><b>1003.11 Toilet and Bathing Facilities.</b> At least one toilet and bathing facility shall comply with Section 1003.11.2. All toilet and bathing facilities shall comply with Section 1003.11.1.</p>	<p><b>1004.11.3 Toilet and Bathing Areas.</b> Either all toilet and bathing areas provided shall comply with Section 1004.11.3.1 (Option A), or one toilet and bathing area shall comply with Section 1004.11.3.2 (Option B).</p>	
	<p><b>1004.11.3.1 Option A.</b> Each fixture provided shall comply with Section 1004.11.3.1.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>Where multiple lavatories are provided in a single toilet and bathing area such that travel between fixtures does not require travel through other parts of the unit, not more than one lavatory is required to comply with Section 1004.11.3.1.</li> <li>A lavatory and a water closet in a room containing only a lavatory and water closet, provided the room does not contain the only lavatory or water closet on the accessible level of the unit.</li> </ol>	<p><b>1004.11.3.2 Option B.</b> One of each type of fixture provided shall comply with Section 1004.11.3.2. The accessible fixtures shall be in a single toilet/bathing area, such that travel between fixtures does not require travel through other parts of the unit.</p>
<p><b>1003.11.2.2 Lavatory.</b> Lavatories shall comply with Section 606.</p> <p><b>EXCEPTION:</b> Cabinetry shall be permitted under the lavatory, provided the following criteria are met:</p> <ol style="list-style-type: none"> <li>The cabinetry can be removed without removal or replacement of the lavatory;</li> <li>The floor finish extends under the cabinetry; and</li> </ol>	<p><b>1004.11.3.1.1 Lavatory.</b> A clear floor space complying with Section 305.3, positioned for a parallel approach, shall be provided at a lavatory. The clear floor space shall be centered on the lavatory.</p> <p><b>EXCEPTION:</b> A lavatory complying with Section 606 shall be permitted. Cabinetry shall be permitted under the lavatory provided the following criteria are met:</p> <ol style="list-style-type: none"> <li>The cabinetry can be removed without removal or replacement of the lavatory; and</li> <li>The floor finish extends under</li> </ol>	<p><b>1004.11.3.2.1 Lavatory.</b> Lavatories shall comply with Sections 1004.11.3.1.1 and 1004.11.3.2.1.</p> <p><i>Same as option A, plus height requirement below.</i></p>


 Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

TOILET AND BATHING FACILITY COMPARISON			
1003 TYPE A DWELLING UNITS		1004 TYPE B DWELLING UNITS	
		OPTION A	OPTION B
	(c) The walls behind and surrounding the cabinetry are finished.	the cabinetry; and (c) The walls behind and surrounding the cabinetry are finished.	
			<b>1004.11.3.2.1.1 Height.</b> The front of the lavatory shall be 34 inches (865 mm) maximum above the floor, measured to the higher of the rim or counter surface.
	<b>1003.11.2.4 Water Closet.</b> Water closets shall comply with Section 1003.11.2.4.	<b>1004.11.3.1.2 Water Closet.</b> The water closet shall comply with Section 1004.11.3.1.2.	<b>1004.11.3.2.2 Water Closet.</b> The water closet shall comply with Section 1004.11.3.1.2.
	<b>1003.11.2.4.1 Location.</b> The water closet shall be positioned with a wall to the rear and to one side. The centerline of the water closet shall be 16 inches (405 mm) minimum and 18 inches (455 mm) maximum from the sidewall.	<b>1004.11.3.1.2.1 Location.</b> The centerline of the water closet shall be 16 inches (405 mm) minimum and 18 inches (455 mm) maximum from one side of the required clearance.	Same as Option A
		<b>1004.11.3.1.2.2 Clearance.</b> Clearance around the water closet shall comply with Sections 1004.11.3.1.2.2.1 through 1004.11.3.1.2.2.3. <b>EXCEPTION:</b> Clearance complying with Sections 1003.11.2.4.2 through 1003.11.2.4.4.	Same as Option A
	<b>1003.11.2.4.2 Clearance Width.</b> A clearance around the water closet shall be 60 inches (1525 mm) minimum in width, measured perpendicular from the side wall.	<b>1004.11.3.1.2.2.1 Clearance Width.</b> Clearance around the water closet shall be 48 inches (1220 mm) minimum in width, measured perpendicular from the side of the clearance that is 16 inches (405 mm) minimum and 18 inches (455 mm) maximum from the water closet centerline.	Same as Option A
	<b>1003.11.2.4.3 Clearance Depth.</b> Clearance around the water closet shall be 56 inches (1420 mm) minimum in depth, measured perpendicular from the rear wall.	<b>1004.11.3.1.2.2.2 Clearance Depth.</b> Clearance around the water closet shall be 56 inches (1420 mm) minimum in depth, measured perpendicular from the rear wall.	Same as Option A
		<b>1004.11.3.1.2.2.3 Increased Clearance Depth at Forward Approach.</b> Where a forward approach is provided, the clearance	Same as Option A


 Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

TOILET AND BATHING FACILITY COMPARISON		
1003 TYPE A DWELLING UNITS	1004 TYPE B DWELLING UNITS	
	OPTION A	OPTION B
	shall be 66 inches (1675 mm) minimum in depth, measured perpendicular from the rear wall.	
<p><b>1003.11.2.4.4 Clearance Overlap.</b> The required clearance around the water closet shall be permitted to overlap the water closet, associated grab bars, paper dispensers, coat hooks, shelves, accessible routes, clear floor space required at other fixtures, and the wheelchair turning space. No other fixtures or obstructions shall be located within the required water closet clearance.</p> <p><b>EXCEPTION:</b> A lavatory measuring 24 inches (610 mm) maximum in depth and complying with Section 1003.11.2.2 shall be permitted on the rear wall 18 inches (455 mm) minimum from the centerline of the water closet to the side edge of the lavatory where the clearance at the water closet is 66 inches (1675 mm) minimum measured perpendicular from the rear wall.</p>	<p><b>1004.11.3.1.2.2.4 Clearance Overlap.</b> A vanity or other obstruction 24 inches (610 mm) maximum in depth, measured perpendicular from the rear wall, shall be permitted to overlap the required clearance, provided the width of the remaining clearance at the water closet is 33 inches (840 mm) minimum.</p>	<p>Same as Option A</p>
<p><b>1003.11.2.5 Bathing Fixtures.</b> The accessible bathing fixture shall be a bathtub complying with Section 1003.11.2.5.1 or a shower compartment complying with Section 1003.11.2.5.2.</p>	<p><b>1004.11.3.1.3 Bathing Fixtures.</b> Where provided, a bathtub shall comply with Section 1004.11.3.1.3.1 or 1004.11.3.1.3.2 and a shower compartment shall comply with Section 1004.11.3.1.3.3.</p>	<p><b>1004.11.3.2.3 Bathing Fixtures.</b> The accessible bathing fixture shall be a bathtub complying with Section 1004.11.3.2.3.1 or a shower compartment complying with Section 1004.11.3.2.3.2</p>
<p><b>1003.11.2.5.1 Bathtub.</b> Bathtubs shall comply with Section 607.</p> <p><b>EXCEPTIONS:</b></p> <ol style="list-style-type: none"> <li>1. The removable in-tub seat required by Section 607.3 is not required.</li> <li>2. Counter tops and cabinetry shall be</li> </ol>		<p><b>1004.11.3.2.3.1 Bathtub.</b> A clearance 48 inches (1220 mm) minimum in length measured perpendicular from the control end of the bathtub, and 30 inches (760 mm) minimum in width shall be provided in front of bathtubs.</p>


 Indicates same language

# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

TOILET AND BATHING FACILITY COMPARISON			
1003 TYPE A DWELLING UNITS		1004 TYPE B DWELLING UNITS	
		OPTION A	OPTION B
	permitted at one end of the clearance, provided the following criteria are met: (a) The countertop and cabinetry can be removed; (b) The floor finish extends under the countertop and cabinetry; and (c) The walls behind and surrounding the countertop and cabinetry are finished.		
		<b>1004.11.3.1.3.1 Parallel Approach Bathtubs.</b> A clearance 60 inches (1525 mm) minimum in length and 30 inches (760 mm) minimum in width shall be provided in front of bathtubs with a parallel approach. Lavatories complying with Section 606 shall be permitted in the clearance. A lavatory complying with Section 1004.11.3.1.1 shall be permitted at one end of the bathtub if a clearance 48 inches (1220 mm) minimum in length and 30 inches (760 mm) minimum in width is provided in front of the bathtub.	
		<b>1004.11.3.1.3.2 Forward Approach Bathtubs.</b> A clearance 60 inches (1525 mm) minimum in length and 48 inches (1220 mm) minimum in width shall be provided in front of bathtubs with a forward approach. A water closet and a lavatory shall be permitted in the clearance at one end of the bathtub.	
	<b>1003.11.2.5.2 Shower.</b> Showers shall comply with Section 608.  <b>EXCEPTION:</b> At standard roll-in shower compartments complying with Section 608.2.2, lavatories, counter tops and cabinetry shall be permitted at one end of the clearance,	<b>1004.11.3.1.3.3 Shower Compartment.</b> If a shower compartment is the only bathing facility, the shower compartment shall have dimensions of 36 inches (915 mm) minimum in width and 36 inches (915 mm) minimum in depth. A clearance of 48 inches (1220 mm) minimum in length, measured perpendicular	<b>1004.11.3.2.3.2 Shower Compartment.</b> A shower compartment shall comply with Section 1004.11.3.1.3.3.  <i>Same as Option A</i>

 Indicates same language



# Accessible / Type A / Type B Dwelling Units

Refer to 2012 NCBC for Scoping and Amendments

2009  
ANSI A117.1

TOILET AND BATHING FACILITY COMPARISON			
1003 TYPE A DWELLING UNITS		1004 TYPE B DWELLING UNITS	
		OPTION A	OPTION B
	provided the following criteria are met: (a) The countertop and cabinetry can be removed; (b) The floor finish extends under the countertop and cabinetry; and (c) The walls behind and surrounding the countertop and cabinetry are finished.	from the shower head wall, and 30 inches (760 mm) minimum in depth, measured from the face of the shower compartment, shall be provided. Reinforcing for a shower seat is not required in shower compartments larger than 36 inches (915 mm) in width and 36 inches (915 mm) in depth.	



Indicates same language