

## PROXIMATE PYROTECHNICS CHECKLIST

(Venue Management)

I. Site Inspection Checklist:		
1.	Confirm venue management consent to pyrotechnics.	
2.	Confirm venue management or production permit for event.	
3.	Verify plot plan measurements and accuracy (NFPA 1126: 4.3.2 (j) and (k) ).	
4.	Verify AHJ approval of venue compliance with life safety standards.	
5.	Determine fire protection systems, controls and equipment.	
6.	Determine HVAC systems and controls.	
7.	Determine show management production plan.	
8.	Determine venue management safety plans, crowd control, security and	
	emergency plans and procedures.	
9.	Determine personal safety requirements for pyrotechnicians (e.g., fall	
	protection plans and equipment).	
10.	Verify AHJ approval of flame retardant materials in public areas and	
	pyrotechnic installation sites.	
11.	Determine approved & secure storage and work areas for pyrotechnics (NFPA	
	1126:3.1.1, 4.3.2 (I) and (m), 6.1.3, 6.1.4).	
12.	Determine hazmat shipping depot (venue) if required.	